

Seismic Evaluation of Nonstructural Components and Non-Building Structures

Rakesh K. Goel, PhD, PE, F.ASCE, F.SEI
Cal Poly, San Luis Obispo
rgoel@calpoly.edu

Objectives

- Review specifications in current MOTEMS
- Identify needs for improvement
- Recommendations



Current MOTEMS Specifications

- 3104F.5.3: Fire protection, emergency shutdown, electrical power systems
 - Reference documents
 - New - None
 - Existing – CalARP (CalARP refers to ASCE 7)
 - Evaluation for survivability and continued operations during Level 1 earthquake

Current MOTEMS Specifications

- 3108F.7: Fire detection, fire protection, emergency shutdown
 - 3104F.5.3 for assessment - Reference documents
 - New - None
 - Existing – CalARP (CalARP refers to ASCE 7)
 - 3110F.8 for anchorage and support – Reference documents
 - New – FEMA 450
 - Existing – Cal ARP, ASCE Guidelines 2011 (both refer to ASCE 7), or FEMA 356

Current MOTEMS Specifications

- 3109F.4: Piping and pipelines
 - Reference documents
 - New – ASCE Guidelines 2011 (refers to ASCE 7)
 - Existing – CalARP (refers to ASCE 7) or FEMA 356

Current MOTEMS Specifications

- 3110F.2.1: Marine Loading Arms
 - Reference documents
 - New – 2CCR 2380, 33CFR 154.5 and OCIMF
 - Existing – 2CCR 2380, 33CFR 154.5 and OCIMF
 - 33CFR indirectly refers to ASCE 7
 - OCIMF is outdated because it refers to UBC

Current MOTEMS Specifications

- 3110F.8: Equipment anchors and supports
 - Reference documents
 - New – FEMA 450
 - Existing – Cal ARP, ASCE Guidelines 2011 (both refer to ASCE 7), or FEMA 356

Current MOTEMS Specifications

- 3110F.11: Critical systems seismic assessment
 - 3104F.5.3 for assessment - Reference documents
 - New - None
 - Existing – CalARP (CalARP refers to ASCE 7)
 - 3110F.8 for anchorage and support – Reference documents
 - New – FEMA 450
 - Existing – Cal ARP, ASCE Guidelines 2011 (both refer to ASCE 7), or FEMA 356

Current MOTEMS Specifications

- 3111F.11: Electrical systems
 - 3104F.5.3 for assessment - Reference documents
 - New - None
 - Existing – CalARP (CalARP refers to ASCE 7)
 - 3110F.8 for anchorage and support – Reference documents
 - New – FEMA 450
 - Existing – Cal ARP, ASCE Guidelines 2011 (both refer to ASCE 7), or FEMA 356



Summary of Current MOTEMS

- Three main reference documents
 - FEMA 450, FEMA 356, and ASCE 7
 - Several other documents (e.g., Cal ARP, ASCE Guidelines 2011, and 33CFR refer back to ASCE 7)
 - OCIMF for Marine Loading Arms is outdated
 - Refers to UBC
- Seismic provisions are spread over multiple chapters
- Lack of clarity on design level earthquake
- Silent on seismic design and assessment of control rooms and other building-like structures mounted on deck



FEMA 450, FEMA 356, ASCE 7 Seismic Force Computation

$$F_p = \frac{0.4a_p S_{DS} W_p}{\frac{R_p}{I_p}} \left(1 + 2 \frac{z}{h} \right)$$

$$0.3S_{DS} I_p W_p < F_p < 1.6S_{DS} I_p W_p$$



FEMA 450, FEMA 356, ASCE 7 Seismic Force Computation

S_{DS} = Short period spectral acceleration

a_p = Component amplification factor

I_p = Component importance factor

R_p = Component response modification factor

W_p = Component operating weight

z = height in structure of point of attachment of component with respect to base

h = average roof height of structure with respect to the base



FEMA 450, FEMA 356, ASCE 7 Seismic Force Computation

- Amplifies ground acceleration, represented by $0.4S_{DS}$, by a factor of $(1+2z/h)$: maximum factor of 3
- Further amplifies acceleration due to flexibility of the component itself by a factor of a_p



FEMA 450, FEMA 356, ASCE 7 Seismic Force Computation

- R_p and a_p values are provided in tables
- $a_p = 1$ for rigid components;
- $a_p = 2.5$ for flexible components
 - Lower value permitted if justified by detailed dynamic analysis
- Types of nonstructural systems included in these documents differs
 - R_p values also may differ slightly



FEMA 450 and ASCE 7 Alternate Equation

- If acceleration, a_i , at the point of attachment of the component can be computed from modal (or response spectrum) method


$$F_p = \frac{a_i a_p W_p}{\frac{R_p}{I_p}} A_x$$



ASCE 7

Alternate Procedure to Estimate a_p


- If fundamental period of the structure, T , and of the component, T_p , are known, a_p may be estimated from





Relationship between a_i and SA

- For low damping values (e.g., 5%), a_i for a SDF system is essentially equal to spectral acceleration





Estimation of a_i

- Marine Oil Terminals are, in most cases, similar to single-degree-of-freedom (SDF) systems
- Damping is typically low (5%)
- For such cases, a_i = spectral acceleration for design earthquake

Recommendations

- Consolidate seismic provisions for nonstructural components
- Compute design forces for MOTEMS Level 2 earthquake
 - $I_p = 1.5$ may be used for critical components to ensure survivability at Level 1 earthquake
- If needed, replace $0.4S_{DS}$ with PGA for MOTEMS design earthquake
- When appropriate, use alternate method with $a_i = SA$ for design earthquake
- When structural and component periods are available, estimate a_p from provided figure



Other Recommendations

- Professionals connected to seismic design of piers and wharves should
 - Identify types of nonstructural and non-building structures typical for Marine Oil Terminals
 - Develop consensus a_p and R_p values if needed
 - Prepare a standard of its own, instead to referring to ASCE 7, if needed